

FIRE SAFETY INSPECTION DIVISION

APPROVED
 DISAPPROVED

Completed

DATE 8/28/00

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and further requiring that you, as owner, agent or person in charge of structure shall have 30 days to complete specified repairs or improvements.

Bus. Phone _____ *Principal Mrs Polizio* Occupant Load _____

Name of facility/Address Georgetown Ele. 1516 K. Leo Blvd.

OCCUPANCY: Business Assembly Storage Education Day Care
Personal Care Home Mercantile Factory Residential Hazardous

*10/13/00
4 months*

- 1. Number of Exit Doors OK 101-SEC 5
- 2. Blocked Locked OK 101-SEC 5
- 3. Exit Sign Good Unsatisfactory NA 101-SEC 5
- 4. Emergency Lights Good Unsatisfactory NA 101-SEC 5
- 5. Panic Hardware Good Unsatisfactory NA 101-SEC 5
- 6. Self-Closing Device Good Unsatisfactory NA
- 7. Fire Alarm Yes No NA NFFA 72
- 8. Smoke/Heat Detectors Yes No NA NFFA 73
- 9. Sprinkler System Yes No NA NFFA 13
- 10. Standpipe Yes No NA NFFA 13
- 11. Number of Fire Extinguishers OK
- Proper Type Yes No NA NFFA 10
- Inspected/Charged Yes No NA May 99 NFFA 10
- 12. Fixed Hood System Yes No NA NFFA 96
- 13. Date of Last Service Aug 2000 REQUIRED EVERY 6 MONTHS
- 14. Electrical Good Fair Unsatisfactory NFFA 70
- 15. Overloaded sockets/outlets Yes No NFFA 70
- 16. Missing electrical covers Yes No NFFA 70
- 17. Other (explain) _____

18. Excessive Storage of Combustibles Yes No NFFA 30

List Details

- OK* (4) Gym - one emergency light inoperative and one emergency light has one bulb inoperative.
- OK* (N/A) Annual fire alarm inspection report is available.
- OK* (N/A) Annual fire sprinkler inspection report available.
- OK* (N/A) No 40 BC fire extinguisher in kitchen, all fire extinguishers are overdue. Have them inspected/tagged annually.

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Lynn Stuckland
Owner/Occupant/Agent Signature

Marion Reynolds
Chatham County Fire Marshall