

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2001

DATE 8/8/01

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and further requiring that you, as owner, agent or person in charge of structure shall have 30 days to complete spec repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____
Name of facility/Address May Howard Elementary 115 W. 2nd St. Rd

OCCUPANCY: Business _____ Assembly _____ Storage _____ Educational _____ Day Care _____
Personal Care Home _____ Mercantile _____ Factory _____ Residential _____ Hazardous _____

- 1. Number of Exit Doors OK 101-SEC 5
- 2. Blocked _____ Locked _____ OK 101-SEC 5
- 3. Exit Sign Good Unsatisfactory _____ NA _____ 101-SEC 5
- 4. Emergency Lights Good Unsatisfactory _____ NA _____ 101-SEC 5
- 5. Panic Hardware Good Unsatisfactory _____ NA _____ 101-SEC 5
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes No _____ NA _____ NFPA 72
- 8. Smoke/Heat Detectors Yes No _____ NA _____ NFPA 73
- 9. Sprinkler System Yes _____ No _____ NA NFPA 13
- 10. Standpipe Yes _____ No _____ NA NFPA 13
- 11. Number of Fire Extinguishers OK
- Proper Type? Yes No _____ NA _____ NFPA 10
- Inspected/Charged Yes No _____ NA _____ NFPA 10
- 12. Fixed Hood System Yes No _____ NA _____ NFPA 98
- 13. Date of Last Service now compliant (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No NFPA 70
- 16. Missing electrical covers Yes _____ No NFPA 70
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No NFPA 30

List Details:
 (18) Remove all combustibles + gasoline from Electrical Rm off Kitchen
 (11) Add fire extinguisher in med/first room
 See Attached sheet

The signature below of Owner, Occupant, Agent, signifies inspection was made.

[Signature]
Owner/Occupant/Agent Signature

[Signature]
Chatham County Fire Marshall