

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
 FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2001

DATE 8/7/01

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and further requiring that you, as owner, agent or person in charge of structure shall have 30 days to complete repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____
 Name of facility/Address Southwest Elementary 8020 Ogdena

OCCUPANCY: Business _____ Assembly _____ Storage _____ Educational _____ Day Care _____
 Personal Care Home _____ Mercantile _____ Factory _____ Residential _____ Hazardous _____

- 1. Number of Exit Doors OK
- 2. Blocked _____ Locked _____ OK 101-SEC 5
- 3. Exit Sign Good Unsatisfactory _____ NA _____ 101-SEC 5
- 4. Emergency Lights Good Unsatisfactory _____ NA _____ 101-SEC 5
- 5. Panic Hardware Good Unsatisfactory _____ NA _____ 101-SEC 5
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____ 101-SEC 5
- 7. Fire Alarm Yes No _____ NA _____
- 8. Smoke/Heat Detectors Yes No _____ NA _____ NFPA 72
- 9. Sprinkler System Yes No Due inspection _____ NA _____ NFPA 73
- 10. Standpipe Yes No _____ NA _____ NFPA 13
- 11. Number of Fire Extinguishers OK
 Proper Type? Yes No _____ NA _____ NFPA 10
 Inspected/Charged Yes No _____ NA _____ NFPA 10
- 12. Fixed Hood System Yes No _____ NA _____ NFPA 96
- 13. Date of Last Service June 01 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No NFPA 70
- 16. Missing electrical covers Yes _____ No NFPA 70
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No NFPA 30

List Details:

OK (9) Have the fire sprinkler system inspected this month
 Several faults on spk system

The signature below of Owner, Occupant, Agent, signifies inspection was made.

R. L. Bell
 Owner/Occupant/Agent Signature

Mark Reynolds
 Chatham County Fire Marshall