

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
 FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2001

DATE 8/10/01

APPROVED

DISAPPROVED

OK TO OPEN
Complaint

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and further requiring that you, as owner, agent or person in charge of structure shall have 8/10/01 days to complete spec repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____
 Name of facility/Address SW middle school 6030 Ogden

OCCUPANCY: Business Assembly Storage Educational Day Care
 Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors 02 101-SEC 5
- 2. Blocked Locked _____ OK _____ 101-SEC 5
- 3. Exit Sign Good _____ Unsatisfactory _____ NA _____ 101-SEC 5
- 4. Emergency Lights Good _____ Unsatisfactory _____ NA _____ 101-SEC 5
- 5. Panic Hardware Good _____ Unsatisfactory _____ NA _____ 101-SEC 5
- 6. Self-Closing Device Good _____ Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes _____ No _____ NA _____ NFPA 72
- 8. Smoke/Heat Detectors Yes _____ No _____ NA _____ NFPA 73
- 9. Sprinkler system Yes _____ No _____ NA _____ NFPA 13
- 10. Standpipe Yes _____ No _____ NA _____ NFPA 13
- 11. Number of Fire Extinguishers _____
 Proper Type? Yes _____ No _____ NA _____ NFPA 10
 Inspected/Charged Yes _____ No _____ NA _____ NFPA 10
- 12. Fixed Hood System Yes _____ No _____ NA _____ NFPA 98
- 13. Date of Last Service _____ (REQUIRED EVERY 6 MONTHS)
- 14. Electrical Good _____ Fair _____ Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No _____ NFPA 70
- 16. Missing electrical covers Yes _____ No _____ NFPA 70
- 17. Other (explain) _____

8/17/01
inspected

18. Excessive Storage of Combustibles Yes _____ No _____ NFPA 30

List Details:
Note - Sprinkler system + Alarm system repaired
OK Hood Fire Suppression system non-compliant - Do NOT COOK until system is compliant

The signature below of Owner, Occupant, Agent, signifies inspection was made.

R. D. Hill
 Owner/Occupant/Agent Signature

Monica L. Reynolds
 Chatham County Fire Marshall