

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2002

DATE 7/22/02

APPROVED
 DISAPPROVED

Completed

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____
Name of facility/Address Georgetown Elementary 1516 King George Blvd

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

*R/14/02 A
1 ASD
101-SEC 5
9/3/02 ASD*

- 1. Number of Exit Doors OK
- 2. Blocked _____ Locked _____ OK
- 3. Exit Sign Good Unsatisfactory _____ NA _____
- 4. Emergency Lights Good Unsatisfactory _____ NA _____
- 5. Panic Hardware Good Unsatisfactory _____ NA _____
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes No _____ NA _____ NFPA 72
- 8. Smoke/Heat Detectors Yes No _____ NA _____ NFPA 73
- 9. Sprinkler System Yes No _____ NA _____ NFPA 13
- 10. Standpipe Yes _____ No _____ NA NFPA 13
- 11. Number of Fire Extinguishers OK
- Proper Type? Yes No _____ NA _____ NFPA 10
- Inspected/Charged Yes No _____ NA _____ NFPA 10
- 12. Fixed Hood System Yes No _____ NA _____ NFPA 96
- 13. Date of Last Service Dec 01 (Overdue) (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No NFPA 70
- 16. Missing electrical covers Yes _____ No NFPA 70
- 17. Other (explain) _____

18. Excessive Storage of Combustibles Yes _____ No NFPA 30

*④ one bulb wop in emergency light in gym (right lean)
④ Sprinkler system due inspection in Aug 02
No fire alarm inspection report was available. LAC, JS School Board EC: 6 A
Add two fire extinguishers in the gym.
Fire Extinguishers Due inspection Aug 02*

The signature below of Owner, Occupant, Agent, signifies inspection was made.
Lynn Steinkland _____ Marion Reynolds _____
Owner/Occupant/Agent Signature Chatham County Fire Marshal

*② Hood fire suppression system overdue (Dec 01).
Clean out excess storage in mechanical rooms + sprinkler riser rooms,*