

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2002

DATE 7/23/02

APPROVED
 DISAPPROVED

Completed

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant/Load _____
Name of facility/Address Sole of Hope Elementary 100 Petersburg Rd

OCCUPANCY: Business _____ Assembly _____ Storage Educational Day Care _____
Personal Care Home _____ Mercantile _____ Factory _____ Residential _____ Hazardous _____

*8/14/02 1 Airtel
8/26/02 2 Airtels*

1. Number of Exit Doors OK
2. Blocked _____ Locked _____ OK ✓
3. Exit Sign Good _____ Unsatisfactory ✓ NA _____ 101-SEC 5
4. Emergency Lights Good _____ Unsatisfactory ✓ NA _____ 101-SEC 5
5. Panic Hardware Good ✓ Unsatisfactory _____ NA _____ 101-SEC 5
6. Self-Closing Device Good ✓ Unsatisfactory _____ NA _____
7. Fire Alarm Yes ✓ No _____ NA _____ NFPA 72
8. Smoke/Heat Detectors Yes ✓ No _____ NA _____ NFPA 79
9. Sprinkler System Yes _____ No _____ NA ✓ NFPA 13
10. Standpipe Yes _____ No _____ NA ✓ NFPA 19
11. Number of Fire Extinguishers OK
 - Proper Type? Yes ✓ No _____ NA _____ NFPA 10
 - Inspected/Charged Yes ✓ No FEA NA _____ NFPA 10
12. Fixed Hood System Yes ✓ No _____ NA _____ NFPA 97
13. Date of Last Service June 02 (REQUIRED EVERY 6 MONTHS)
14. Electrical Good ✓ Fair _____ Unsatisfactory _____ NFPA 70
15. Overloaded sockets/outlets Yes _____ No ✓ NFPA 70
16. Missing electrical covers Yes _____ No ✓ NFPA 70
17. Other (explain) _____
18. Excessive Storage of Combustibles Yes _____ No ✓ NFPA 30

List Details:
 (3) Several Exit signs are not lit and/or the battery back-up systems
 (4) Several Emergency lights are inoperative
 (7) Fire alarm panel has two troubles. Have the system repaired/inspected + certified.
 Letter to GA & School board to properly insp. Alarm Systems

The signature below of Owner, Occupant, Agent, signifies inspection was made

Dorothy Greer
Owner/Occupant/Agent Signature

Manon L. Kenneth
Chatham County Fire Marshal