

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES  
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2002

DATE July 23, 2002  
8-15-02  
9-18-02

*5 wings  
8 portables*

       APPROVED  
       DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 10 days to complete specified repairs or improvements.

Bus. Phone \_\_\_\_\_ Owner \_\_\_\_\_ Occupant Load \_\_\_\_\_

Name of facility/Address May Haisard Elementary

OCCUPANCY: Business \_\_\_\_\_ Assembly \_\_\_\_\_ Storage   Educational   Day Care \_\_\_\_\_  
Personal Care Home \_\_\_\_\_ Mercantile \_\_\_\_\_ Factory \_\_\_\_\_ Residential \_\_\_\_\_ Hazardous \_\_\_\_\_

- 1. Number of Exit Doors 16 10 101-SEC 5
- 2. Blocked \_\_\_\_\_ Locked \_\_\_\_\_ OK   ✓   101-SEC 5
- 3. Exit Sign Good \_\_\_\_\_ Unsatisfactory   ✓   NA \_\_\_\_\_ 101-SEC 5
- 4. Emergency Lights Good \_\_\_\_\_ Unsatisfactory   ✓   NA \_\_\_\_\_ 101-SEC 5
- 5. Panic Hardware Good \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NA   ✓   101-SEC 5
- 6. Self-Closing Device Good   ✓   Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_
- 7. Fire Alarm Yes   ✓   No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 72
- 8. Smoke/Heat Detectors Yes   ✓   No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 73
- 9. Sprinkler System Yes   ✓   No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 13
- 10. Standpipe Yes \_\_\_\_\_ No \_\_\_\_\_ NA   ✓   NFPA 13
- 11. Number of Fire Extinguishers 28
  - Proper Type? Yes   ✓   No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 10
  - Inspected/Charged Yes \_\_\_\_\_ No   ✓   NA \_\_\_\_\_ NFPA 10
- 12. Fixed Hood System Yes   ✓   No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 98
- 13. Date of Last Service 6/02 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good   ✓   Fair \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NFPA 70
- 15. Overloaded sockets/outlets Yes \_\_\_\_\_ No   ✓   NFPA 70
- 16. Missing electrical covers Yes \_\_\_\_\_ No   ✓   NFPA 70
- 17. Other (explain) Broken light fixture blocking sprinkler in janitor's closet wing 2
- 18. Excessive Storage of Combustibles Yes \_\_\_\_\_ No   ✓   NFPA 30

*8-15-02  
OK*

List Details:

- 1. Exit signs - cafeteria, wing 3, 4, 4A, 5B, wing 5 *Rem 16*
- 2. Emergency light - gym
- 3. Needs fire alarm certification
- 4. Needs sprinkler certification

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Michael Brown  
Owner/Occupant/Agent Signature

Stephanie Waters  
Chatham County Fire Marshall

*OK 8-15-02*  
~~exit/tag fire extinguishers - cafeteria, media center, gym~~