

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2002

DATE July 26, 2002

10AM
Wed

APPROVED
 DISAPPROVED

Complete

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 7 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____
Name of facility/Address Oatland Island Education Center

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

1 portable
OK

- 1. Number of Exit Doors 6 101-SEC 5
- 2. Blocked Locked OK 101-SEC 5
- 3. Exit Sign Good _____ Unsatisfactory _____ NA _____ 101-SEC 5
- 4. Emergency Lights Good _____ Unsatisfactory _____ NA _____ 101-SEC 5
- 5. Panic Hardware Good _____ Unsatisfactory _____ NA _____ 101-SEC 5
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes _____ No _____ NA _____ NFPA 72
- 8. Smoke/Heat Detectors Yes _____ No _____ NA _____ NFPA 73
- 9. Sprinkler System Yes _____ No _____ NA _____ NFPA 13
- 10. Standpipe Yes _____ No _____ NA _____ NFPA 13
- 11. Number of Fire Extinguishers 11 Nov 14, 2001
Proper Type? Yes No _____ NA _____ NFPA 10
Inspected/Charged Yes No _____ NA _____ NFPA 10
- 12. Fixed Hood System Yes _____ No _____ NA _____ NFPA 98
- 13. Date of Last Service _____ (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good _____ Fair Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No _____ NFPA 70
- 16. Missing electrical covers Yes No _____ NFPA 70
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No NFPA 30

List Details:

- 13 Exit light battery backup inoperable conference room
- 15 Extension cords at reception
- 16 need face plate on switch @ refing, Breaker cover basement AC panel
- 17 Emergency light conference room

The signature below of Owner, Occupant, Agent, signifies inspection was made.

[Signature]
Owner/Occupant/Agent Signature

Alphonette Waters
Chatham County Fire Marshall

Bryan Stewart
201-5230
603-1573 cell.

fire pump inoperable
stand pipe ?