

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2002

DATE 7/22/02

APPROVED
 DISAPPROVED

Completed

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus, Phone _____ Owner _____ Occupant Load _____
Name of facility/Address Southwest Elementary 6020 Oysterlee

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors OK
2. Blocked Locked _____ OK
3. Exit Sign Good Unsatisfactory _____ NA _____
4. Emergency Lights Good Unsatisfactory _____ NA _____
5. Panic Hardware Good Unsatisfactory _____ NA _____
6. Self-Closing Device Good Unsatisfactory _____ NA _____
7. Fire Alarm Yes No _____ NA _____
8. Smoke/Heat Detectors Yes No _____ NA _____
9. Sprinkler System Yes No _____ NA _____
10. Standpipe Yes _____ No _____ NA NFPA 13
11. Number of Fire Extinguishers OK
 - Proper Type? Yes No _____ NA _____
 - Inspected/Charged Yes _____ No June 01 NA _____
12. Fixed Hood System Yes No _____ NA _____
13. Date of Last Service June 02 (REQUIRED EVERY 6 MONTHS) NA _____
14. Electrical: Good Fair _____ Unsatisfactory _____ NFPA 70
15. Overloaded sockets/outlets Yes _____ No NFPA 70
16. Missing electrical covers Yes _____ No NFPA 70
17. Other (explain) _____
18. Excessive Storage of Combustibles Yes _____ No NFPA 30

*8/6/02 1 Added
8/28/02 2 Added
101-SEC 5
9/3/02 1 Added
101-SEC 5
101-SEC 5
101-SEC 5*

- List Defects
- ③ One emergency light in Boys Bathroom (Main Hall Near Office)*
 - ④ Have the fire alarm inspected + certified + is inoperative*
 - ⑤ Have the fire sprinkler system inspected / tagged on Aug 2 2002*
 - ⑥ Have the fire extinguishers inspected + tagged*

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Joseph Hopkins
Owner/Occupant/Agent Signature

Mum Reynolds
Chatham County Fire Marshall