

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2003

DATE July 24, 2003
8-27-03
9-30-03

U
APPROVED
DISAPPROVED

Complete

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 17 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____

Name of facility/Address Coastal Middle School 170 Whitmarsh Rd

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors _____
- 2. Blocked _____ Locked _____ OK
- 3. Exit Sign Good _____ Unsatisfactory _____ NA _____
- 4. Emergency Lights Good Unsatisfactory _____ NA _____
- 5. Panic Hardware Good Unsatisfactory _____ NA _____
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes No _____ NA _____
- 8. Smoke/Heat Detectors Yes No _____ NA _____
- 9. Sprinkler System Yes _____ No NA _____
- 10. Standpipe Yes _____ No NA _____
- 11. Number of Fire Extinguishers 1-1111111111 Feb 2004
Proper Type? Yes No _____ NA _____
Inspected/Charged Yes No _____ NA _____
- 12. Fixed Hood System Yes No _____ NA _____
- 13. Date of Last Service July 8, 2003 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____
- 15. Overloaded sockets/outlets Yes _____ No
- 16. Missing electrical covers Yes _____ No
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No

List Details:

OK Exit light not lit @ 634, 834, 218 Backup ofc.
OK Need Alarm Certification

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Bernard G...
Owner/Occupant/Agent Signature

Alphonso Waters
Chatham County Fire Marshal