

RC Hall

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2003

DATE 7/24/03

APPROVED
 DISAPPROVED

Completed

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____

Name of facility/Address Georgetown Elementary 1516 K. George Blvd.

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors OK
- 2. Blocked _____ Locked _____ OK
- 3. Exit Sign Good Unsatisfactory _____ NA _____
- 4. Emergency Lights Good Unsatisfactory _____ NA _____
- 5. Panic Hardware Good Unsatisfactory _____ NA _____
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes No _____ NA _____
- 8. Smoke/Heat Detectors Yes No _____ NA _____
- 9. Sprinkler System Yes No Aug 03 NA _____
- 10. Standpipe Yes _____ No _____ NA
- 11. Number of Fire Extinguishers OK
- Proper Type? Yes No _____ NA _____
- Inspected/Charged Yes No Aug 03 NA _____
- 12. Fixed Hood System Yes No June 03 NA _____
- 12. Date of Last Service _____ (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____
- 15. Overloaded sockets/outlets Yes _____ No
- 16. Missing electrical covers Yes _____ No
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No

8/18/03 1 Arrested 101-SEC 5
8/20/03 1 Arrested 101-SEC 5
8/26/03 1 Arrested 101-SEC 5
9/5/03 1 Arrested 101-SEC 5
9/10/03 1 Arrested NFFA 72

List Details:
OK ⑦ No fire alarm Report is available
OK ⑧ The fire sprinkler system is due inspection Aug 03
OK ⑩ The fire Extinguishers are due inspection Aug 03

The signature below of Owner, Occupant, Agent, signifies inspection was made.

[Signature]
Owner/Occupant/Agent Signature

[Signature]
Chatham County Fire Marshall