CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION
YEAR OF: 2003

✓ APPROVED
___ DISAPPROVED

DATE July 24, 2003

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and fu that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____

Name of facility/Address Islands Elementary 4595 Hwy 80E

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors ✓				101-SEC 5
2. Blocked ___ Locked ___ OK ✓				101-SEC 5
3. Exit Sign	Good ___	Unsatisfactory ✓	NA ___	101-SEC 5
4. Emergency Lights	Good ✓	Unsatisfactory ___	NA ___	101-SEC 5
5. Panic Hardware	Good ✓	Unsatisfactory ___	NA ___	101-SEC 5
6. Self-Closing Device	Good ✓	Unsatisfactory ___	NA ___	
7. Fire Alarm	Yes ✓	No ___	NA ___	NFPA 72
8. Smoke/Heat Detectors	Yes ✓	No ___	NA ___	NFPA 73
9. Sprinkler System	Yes ✓	No ___	NA ___ Jan 23, 2003	NFPA 13
10. Standpipe	Yes ___	No ___	NA ___	NFPA 13
11. Number of Fire Extinguishers ___				
Proper Type?	Yes ___	No ___	NA ___	NFPA 10
Inspected/Charged	Yes ___	No ___	NA ___	NFPA 10
12. Fixed Hood System	Yes ✓	No ___	NA ___	NFPA 96
13. Date of Last Service July 7, 2003 (REQUIRED EVERY 6 MONTHS)				
14. Electrical:	Good ___	Fair ___	Unsatisfactory ___	NFPA 70
15. Overloaded sockets/outlets	Yes ___	No ___		NFPA 70
16. Missing electrical covers	Yes ___	No ___		NFPA 70
17. Other (explain) ~~Intercom Portable 55~~				
18. Excessive Storage of Combustibles	Yes ___	No ✓		NFPA 30

List Details:

3 Backup inoperable Admin., @ cafeteria (one side), @ custodian across from cafeteria. Not lit portable 54, @ art room

8 No detector in 56

The signature below of Owner, Occupant, Agent, signifies Inspection was made.

Sharon Wells
Owner/Occupant/Agent Signature

Alphanette Waters
Chatham County Fire Marshall

i:\forms\fire.inp1

7 Needs annual fire alarm certification

9 Needs sprinkler certification