

*Bryan Stewart*

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES  
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2003

DATE 7/23/03

APPROVED  
 DISAPPROVED

*Completed*

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and further that you, as owner, agent or person in charge of structure shall have \_\_\_\_\_ days to complete specified repairs or improvements.

Bus. Phone \_\_\_\_\_ Owner Linda Olson *Principal*  
Occupant Load \_\_\_\_\_

Name of facility/Address Jole of Hope Elementary 180 Parkersburg Road

OCCUPANCY: Business Assembly Storage Educational Day Care  
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors DIL 8/11/03 *1 Assisted* 101-SEC 5
- 2. Blocked \_\_\_\_\_ Locked \_\_\_\_\_ OK  8/26/03 *1 Assisted* 101-SEC 5
- 3. Exit Sign Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 8/26/03 *1 Assisted* 101-SEC 5
- 4. Emergency Lights Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 5. Panic Hardware Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 10/6/03 *1 Assisted* 101-SEC 5
- 6. Self-Closing Device Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ System Tested
- 7. Fire Alarm Yes  No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 72
- 8. Smoke/Heat Detectors Yes \_\_\_\_\_ No \_\_\_\_\_ NA  NFPA 73
- 9. Sprinkler System Yes \_\_\_\_\_ No \_\_\_\_\_ NA  NFPA 13
- 10. Standpipe Yes \_\_\_\_\_ No \_\_\_\_\_ NA  NFPA 13
- 11. Number of Fire Extinguishers OK
- Proper Type? Yes  No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 10
- Inspected/Charged Yes  No July 03 NA \_\_\_\_\_ NFPA 10
- 12. Fixed Hood System Yes  No Non-compliant NA \_\_\_\_\_ NFPA 96
- 13. Date of Last Service \_\_\_\_\_ (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good  Fair \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NFPA 70
- 15. Overloaded sockets/outlets Yes \_\_\_\_\_ No  NFPA 70
- 16. Missing electrical covers Yes \_\_\_\_\_ No  NFPA 70
- 17. Other (explain) \_\_\_\_\_
- 18. Excessive Storage of Combustibles Yes \_\_\_\_\_ No  NFPA 30

List Details:

*10* No Report available  
*12* The Hood fire suppression system is Non-compliant  
Have the system Repaired as necessary  
*Completed by Alphannette*

The signature below of Owner, Occupant, Agent, signifies inspection was made.

*Linda Olson*  
Owner/Occupant/Agent Signature  
Lifeline: 1-800-368-7233

*Matthew L. Kumpel*  
Chatham County Fire Marshall

*Pye-Barker - Hood system*  
*mette Farnan*  
*313-9987*

*8/26/03* | *System installed*  
*But No Shunt Trips*  
*Installed.*