

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES  
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2003

DATE 7-24-03  
8-27-03

APPROVED  
DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone \_\_\_\_\_ Owner \_\_\_\_\_ Occupant Load \_\_\_\_\_

Name of facility/Address Marshport Elem. 135 Whitmarsh Isl

OCCUPANCY: Business Assembly Storage Educational Day Care  
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors \_\_\_\_\_
- 2. Blocked \_\_\_\_\_ Locked \_\_\_\_\_ OK ✓ 101-SEC 5
- 3. Exit Sign \_\_\_\_\_ Good \_\_\_\_\_ Unsatisfactory ✓ NA \_\_\_\_\_ 101-SEC 5
- 4. Emergency Lights \_\_\_\_\_ Good \_\_\_\_\_ Unsatisfactory ✓ NA \_\_\_\_\_ 101-SEC 5
- 5. Panic Hardware \_\_\_\_\_ Good ✓ Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 6. Self-Closing Device \_\_\_\_\_ Good ✓ Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_
- 7. Fire Alarm \_\_\_\_\_ Yes ✓ No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 72
- 8. Smoke/Heat Detectors \_\_\_\_\_ Yes \_\_\_\_\_ No ✓ NA \_\_\_\_\_ NFFA 73
- 9. Sprinkler System \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 13
- 10. Standpipe \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 13
- 11. Number of Fire Extinguishers 227 ~~111111111111111111~~ 11  
Proper Type? \_\_\_\_\_ Yes ✓ No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 10  
Inspected/Charged \_\_\_\_\_ Yes ✓ No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 10
- 12. Fixed Hood System \_\_\_\_\_ Yes ✓ No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 25
- 13. Date of Last Service July 8, 2003 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: \_\_\_\_\_ Good ✓ Fair \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NFFA 70
- 15. Overloaded sockets/outlets \_\_\_\_\_ Yes \_\_\_\_\_ No ✓ NFFA 70
- 16. Missing electrical covers \_\_\_\_\_ Yes \_\_\_\_\_ No ✓ NFFA 70
- 17. Other (explain) \_\_\_\_\_
- 18. Excessive Storage of Combustibles Yes \_\_\_\_\_ No ✓ NFFA 30

List Details: ~~Kitchen both sides, 306, 311, 314, 315, 316, 317, 318, 319, 320, 321, 322, 323, 324, 325, 326, 327, 328, 329, 330, 331, 332, 333, 334, 335, 336, 337, 338, 339, 340, 341, 342, 343, 344, 345, 346, 347, 348, 349, 350, 351, 352, 353, 354, 355, 356, 357, 358, 359, 360, 361, 362, 363, 364, 365, 366, 367, 368, 369, 370, 371, 372, 373, 374, 375, 376, 377, 378, 379, 380, 381, 382, 383, 384, 385, 386, 387, 388, 389, 390, 391, 392, 393, 394, 395, 396, 397, 398, 399, 400, 401, 402, 403, 404, 405, 406, 407, 408, 409, 410, 411, 412, 413, 414, 415, 416, 417, 418, 419, 420, 421, 422, 423, 424, 425, 426, 427, 428, 429, 430, 431, 432, 433, 434, 435, 436, 437, 438, 439, 440, 441, 442, 443, 444, 445, 446, 447, 448, 449, 450, 451, 452, 453, 454, 455, 456, 457, 458, 459, 460, 461, 462, 463, 464, 465, 466, 467, 468, 469, 470, 471, 472, 473, 474, 475, 476, 477, 478, 479, 480, 481, 482, 483, 484, 485, 486, 487, 488, 489, 490, 491, 492, 493, 494, 495, 496, 497, 498, 499, 500~~  
 ④ ~~@ 150, 209, 407, gym on east side, 304, one light, rt side near cafe~~  
 ⑤ No smoke detectors 401/402, portables ~~not working left no~~

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Trudette Christie  
Owner/Occupant/Agent Signature

Alphonse Waters  
Chatham County Fire Marshall

③ Exit sign backup inoperable @ 325, cafeteria near 314, 311 (storage)  
 Needs his alarm articulation