

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES  
 FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2003

DATE 7-25-03

APPROVED  
 DISAPPROVED

Complete w/ Bryan 8-27-03

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone \_\_\_\_\_ Owner \_\_\_\_\_ Occupant Load \_\_\_\_\_

Name of facility/Address May Howard Elem. Wilmers Rd

OCCUPANCY: Business Assembly Storage Educational Day Care  
 Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors \_\_\_\_\_
2. Blocked \_\_\_\_\_ Locked \_\_\_\_\_ OK
3. Exit Sign Good \_\_\_\_\_ Unsatisfactory  NA \_\_\_\_\_ 101-SEC 5
4. Emergency Lights Good \_\_\_\_\_ Unsatisfactory  NA \_\_\_\_\_ 101-SEC 5
5. Panic Hardware Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
6. Self-Closing Device Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_
7. Fire Alarm Yes  No \_\_\_\_\_ NA \_\_\_\_\_
8. Smoke/Heat Detectors Yes \_\_\_\_\_ No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 72
9. Sprinkler System Yes \_\_\_\_\_ No  NA \_\_\_\_\_ NFFA 73
10. Standpipe Yes \_\_\_\_\_ No  NA \_\_\_\_\_ NFFA 13
11. Number of Fire Extinguishers \_\_\_\_\_  
 Proper Type? Yes  No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 13  
 Inspected/Charged Yes  No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 10
12. Fixed Hood System Yes  No \_\_\_\_\_ NA \_\_\_\_\_ NFFA 10
13. Date of Last Service July 8 2003 (REQUIRED EVERY 6 MONTHS) NA \_\_\_\_\_ NFFA 98
14. Electrical: Good \_\_\_\_\_ Fair \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NFFA 70
15. Overloaded sockets/outlets Yes \_\_\_\_\_ No  NFFA 70
16. Missing electrical covers Yes \_\_\_\_\_ No  NFFA 70
17. Other (explain) entracecom inoperable NFFA 70
18. Excessive Storage of Combustibles Yes \_\_\_\_\_ No  NFFA 30

List Details:

OK (1) 19, 51, 50, 52  
 OK (2) Sign not lit 52, 51, 53 Wing 5  
 OK (3) 44, 41, 45

The signature below of Owner, Occupant, Agent, signifies inspection was made.

[Signature]  
 Owner/Occupant/Agent Signature

Alphonette Waters  
 Chatham County Fire Marshall

OK (4) Open (for night)