

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES  
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2003

DATE 7-31-03

APPROVED  
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and for that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone \_\_\_\_\_ Owner \_\_\_\_\_ Occupant Load \_\_\_\_\_

Name of facility/Address Oakland Island Education Center

OCCUPANCY: Business Assembly Storage Educational Day Care  
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors 7 + 101-SEC 5
- 2. Blocked \_\_\_\_\_ Locked \_\_\_\_\_ OK  101-SEC 5
- 3. Exit Sign Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 4. Emergency Lights Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 5. Panic Hardware Good \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NA  101-SEC 5
- 6. Self-Closing Device Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_
- 7. Fire Alarm Yes \_\_\_\_\_ No \_\_\_\_\_ NA  NFPA 72
- 8. Smoke/Heat Detectors Yes \_\_\_\_\_ No \_\_\_\_\_ NA  NFPA 73
- 9. Sprinkler System Yes \_\_\_\_\_ No \_\_\_\_\_ NA  NFPA 13
- 10. Standpipe Yes \_\_\_\_\_ No \_\_\_\_\_ NA  NFPA 13
- 11. Number of Fire Extinguishers 10 ~~11~~ ~~12~~ ~~13~~ ~~14~~ ~~15~~
  - Proper Type? Yes  No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 10
  - Inspected/Charged Yes  No  NA \_\_\_\_\_ NFPA 10
- 12. Fixed Hood System Yes \_\_\_\_\_ No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 95
- 13. Date of Last Service \_\_\_\_\_ (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good  Fair \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NFPA 70
- 15. Overloaded sockets/outlets Yes \_\_\_\_\_ No  NFPA 70
- 16. Missing electrical covers Yes \_\_\_\_\_ No  NFPA 70
- 17. Other (explain) \_\_\_\_\_
- 18. Excessive Storage of Combustibles Yes \_\_\_\_\_ No  NFPA 30

List Details:

⑪ Set & tag extinguishers in work room and food room. Not checked since 2001

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Marie [Signature]  
Owner/Occupant/Agent Signature

Alphonso [Signature]  
Chatham County Fire Marshall