

RL 10/11

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2003

DATE 7/23/03

APPROVED
 DISAPPROVED

Completed

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and that you, as owner, agent or person in charge of structure shall have 14 days to complete specified repairs or improvements.

Bus. Phone _____ Owner Middle Occupant Load _____

Name of facility/Address Southwest Elementary School 1030 Oyster

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

*7/30/03 1 Assesd
8/25/03 1 Assesd
9/10/03 1 Assesd*

- 1. Number of Exit Doors OK
- 2. Blocked _____ Locked _____ OK
- 3. Exit Sign Good Unsatisfactory _____ NA _____
- 4. Emergency Lights Good Unsatisfactory _____ NA _____
- 5. Panic Hardware Good Unsatisfactory _____ NA _____
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes No Trouble NA _____
- 8. Smoke/Heat Detectors Yes No _____ NA _____
- 9. Sprinkler System Yes No Aug 02 NA _____
- 10. Standpipes Yes _____ No _____ NA
- 11. Number of Fire Extinguishers OK
- Proper Type? Yes No _____ NA _____
- Inspected/Charged Yes No Aug 02 NA _____
- 12. Faced Hood System Yes No _____ NA _____
- 13. Date of Last Service June 03 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____
- 15. Overloaded sockets/outlets Yes _____ No
- 16. Missing electrical covers Yes _____ No
- 17. Other (explain) _____

18. Excessive Storage of Combustibles Yes No Normal Operation NFPA 30

List Details:
OK (i) The fire Alarm is in trouble. This system must be operational prior to school opening
OK (ii) Gym sprinkler system due inspection Aug 03
OK (iii) The fire extinguishers are due Aug 03

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Larry B. Hill
Owner/Occupant/Agent Signature

Maureen Reynolds
Chatham County Fire Marshall

22/36 FE need service W.O. sent.