

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
 FIRE SAFETY INSPECTION DIVISION
 YEAR OF: 2004

DATE 8-5-04

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further that you, as owner, agent or person in charge of structure shall have 7 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____

Name of facility/Address Bergetown Elem. School 1516 King George Blvd

OCCUPANCY: Business Assembly Storage Educational Day Care
 Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors	_____			101-SEC 5
2. Blocked	Locked _____	OK <input checked="" type="checkbox"/>		101-SEC 5
3. Exit Sign	Good _____	Unsatisfactory <input checked="" type="checkbox"/>	NA _____	101-SEC 5
4. Emergency Lights	Good _____	Unsatisfactory <input checked="" type="checkbox"/>	NA _____	101-SEC 5
5. Panic Hardware	Good <input checked="" type="checkbox"/>	Unsatisfactory _____	NA _____	
6. Self-Closing Device	Good <input checked="" type="checkbox"/>	Unsatisfactory _____	NA _____	
7. Fire Alarm	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 72
8. Smoke/Heat Detectors	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 73
9. Sprinkler System	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 13
10. Standpipe	Yes _____	No _____	NA <input checked="" type="checkbox"/>	NFPA 13
11. Number of Fire Extinguishers	<u>44</u> <u>1111</u>			
Proper Type?	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 10
Inspected/Charged	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 10
12. Fixed Hood System	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 96
13. Date of Last Service	<u>June 8, 2004</u>		(REQUIRED EVERY 6 MONTHS)	
14. Electrical:	Good <input checked="" type="checkbox"/>	Fair _____	Unsatisfactory _____	NFPA 70
15. Overloaded sockets/outlets	Yes _____	No <input checked="" type="checkbox"/>		NFPA 70
16. Missing electrical covers	Yes <input checked="" type="checkbox"/>	No _____		NFPA 70
17. Other (explain)	<u>Remove banner from ceiling in corridors to cafeteria (blocking exit sign)</u>			NFPA 30
18. Excessive Storage of Combustibles	Yes _____	No <input checked="" type="checkbox"/>		

Due 8-8-04
Due Oct 2004

List Details:

- ① Emergency light inoperable - night near gym
- ② Remove storage from sprinkler user room - Annual cert. due
- ③ Exit sign inoperable @ 35, 9
- ④ Receptacle covers missing in closet @ computer lab #1

The signature below of Owner, Occupant, Agent, signifies inspection was made.

James W. Davis
 Owner/Occupant/Agent Signature

Alphonso Waters
 Chatham County Fire Marshal