CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION
YEAR OF: 2004

DATE 8-3-04

✓ APPROVED
_____ DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further req that you, as owner, agent or person in charge of structure shall have 7 days to complete specified repairs or improvements.

Bus. Phone_____ Owner_____ Occupant Load_____

Name of facility/Address Isle of Hope Elem. School ; Parkersburg

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors ✓				101-SEC 5
2. Blocked_____ Locked_____ OK ✓				101-SEC 5
3. Exit Sign	Good_____	Unsatisfactory ✓	NA_____	101-SEC 5
4. Emergency Lights	Good_____	Unsatisfactory ✓	NA_____	101-SEC 5
5. Panic Hardware	Good_____	Unsatisfactory_____	NA ✓	101-SEC 5
6. Self-Closing Device	Good ✓	Unsatisfactory_____	NA_____	
7. Fire Alarm	Yes ✓	No_____	NA_____	NFPA 72
8. Smoke/Heat Detectors	Yes ✓	No_____	NA_____	NFPA 73
9. Sprinkler System	Yes_____	No_____	NA ✓	NFPA 13
10. Standpipe	Yes_____	No_____	NA ✓	NFPA 13
11. Number of Fire Extinguishers ~~IIII IIII IIII IIII~~		May 2004		
Proper Type?	Yes ✓	No_____	NA_____	NFPA 10
Inspected/Charged	Yes ✓	No_____	NA_____	NFPA 10
12. Fixed Hood System	Yes ✓	No_____	NA_____ Jun 04	NFPA 96
13. Date of Last Service _____ (REQUIRED EVERY 6 MONTHS)				
14. Electrical:	Good ✓	Fair_____	Unsatisfactory_____	NFPA 70
15. Overloaded sockets/outlets	Yes_____	No ✓		NFPA 70
16. Missing electrical covers	Yes_____	No ✓		NFPA 70
17. Other (explain)_____				
18. Excessive Storage of Combustibles	Yes_____	No ✓		NFPA 30

List Details:

(4) Em. light cafeteria dble door far side
(3) Remove banner that obstruct exit signs. Sign between 41/42
(7) Needs fire alarm certification device in 34 enabled
intercom in 42 disabled
(8) Smoke detector 4[illegible], 44

The signature below of Owner, Occupant, Agent, signifies Inspection was made.

Isaiah Brown
Owner/Occupant/Agent Signature

Alphonetta Hatus
Chatham County Fire Marshal