

FIRE SAFETY INSPECTION DIVISION  
 YEAR OF: 2004

DATE 8-6-04

APPROVED  
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and for that you, as owner, agent or person in charge of structure shall have 30 days to complete specified repairs or improvements.

Bus. Phone 898-3980 Owner \_\_\_\_\_ Occupant Load \_\_\_\_\_

Name of facility/Address Oakland Island Education Center 711 Sandtown Rd.

OCCUPANCY: Business Assembly Storage Educational Day Care  
 Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors 7
- 2. Blocked \_\_\_\_\_ Locked \_\_\_\_\_ OK  101-SEC 5
- 3. Exit Sign Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 4. Emergency Lights Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 5. Panic Hardware Good \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 6. Self-Closing Device Good  Unsatisfactory \_\_\_\_\_ NA \_\_\_\_\_ 101-SEC 5
- 7. Fire Alarm Yes \_\_\_\_\_ No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 72
- 8. Smoke/Heat Detectors Yes \_\_\_\_\_ No  NA \_\_\_\_\_ NFPA 72
- 9. Sprinkler System Yes \_\_\_\_\_ No  NA \_\_\_\_\_ NFPA 13
- 10. Standpipe Yes \_\_\_\_\_ No  NA \_\_\_\_\_ NFPA 13
- 11. Number of Fire Extinguishers 12
- Proper Type? Yes  No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 10
- Inspected/Charged Yes \_\_\_\_\_ No  NA \_\_\_\_\_ NFPA 10
- 12. Fixed Hood System Yes \_\_\_\_\_ No  NA \_\_\_\_\_ NFPA 95
- 13. Date of Last Service \_\_\_\_\_ (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good  Fair \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NFPA 70
- 15. Overloaded sockets/outlets Yes \_\_\_\_\_ No  NFPA 70
- 16. Missing electrical covers Yes \_\_\_\_\_ No  NFPA 70
- 17. Other (explain) \_\_\_\_\_
- 18. Excessive Storage of Combustibles Yes \_\_\_\_\_ No  NFPA 30

List Details:

- 3 one exit light in meeting room backup light blown
- 11 extinguishers need to be test and tagged

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Maible V. Pitt  
 Owner/Occupant/Agent Signature

Mychal Lee  
 Chatham County Fire Marshal