

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
 FIRE SAFETY INSPECTION DIVISION
 YEAR OF: 2004

DATE 8-4-04

APPROVED
 DISAPPROVED

Fax to R.L. Hill

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further rec that you, as owner, agent or person in charge of structure shall have 7 days to complete specified repairs or improvements.

Bus. Phone _____ Owner _____ Occupant Load _____

Name of facility/Address Southwest Elementary 6020 Oglethorpe Rd

OCCUPANCY: Business Assembly Storage Educational Day Care
 Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors	_____	_____	_____	101-SEC 5
2. Blocked	Locked _____	OK _____	_____	101-SEC 5
3. Exit Sign	Good <input checked="" type="checkbox"/>	Unsatisfactory _____	NA _____	101-SEC 5
4. Emergency Lights	Good _____	Unsatisfactory <input checked="" type="checkbox"/>	NA _____	101-SEC 5
5. Panic Hardware	Good _____	Unsatisfactory _____	NA _____	101-SEC 5
6. Self-Closing Device	Good _____	Unsatisfactory _____	NA _____	
7. Fire Alarm	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 72
8. Smoke-Heat Detectors	Yes _____	No _____	NA _____	NFPA 72
9. Sprinkler System	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 13
10. Standpipe	Yes _____	No _____	NA _____	NFPA 13
11. Number of Fire Extinguishers	<u>21</u>	_____	_____	
Proper Type?	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 10
Inspected/Charged	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 10
12. Fixed Hood System	Yes <input checked="" type="checkbox"/>	No _____	NA _____	NFPA 9C
13. Date of Last Service	<u>June 2004</u>	_____	_____	(REQUIRED EVERY 6 MONTHS)
14. Electrical:	Good <input checked="" type="checkbox"/>	Fair _____	Unsatisfactory _____	NFPA 70
15. Overloaded sockets/outlets	Yes _____	No <input checked="" type="checkbox"/>	_____	NFPA 70
16. Missing electrical covers	Yes <input checked="" type="checkbox"/>	No _____	_____	NFPA 70
17. Other (explain)	_____			
18. Excessive Storage of Combustibles	Yes _____	No <input checked="" type="checkbox"/>	_____	NFPA 30

List Details:

Needs weatherproof cover @ front entrance
 Emergency lights inoperable @ 120, Wing 1 IDF, 107, Wing 300 Rm 301, 306, 307, 305, 415, 211, Wing 2 IDF, Wing 2 Bay restroom, @ 201 D, Wing 5E IDF, cafeteria left rear
 Needs Fire Alarm Certification
 Needs Sprinkler System Certification (Due 8-8-04)

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Augusta Wiggins
 Owner/Occupant/Agent Signature

Alphonso Waters
 Chatham County Fire Marshal