

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES

FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2006

DATE 10/18/06

APPROVED
DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further req that you, as owner, agent or person in charge of structure shall have days to complete specified repairs or improvements.

STUD: 715
STAFF: 90
805

Bus. Phone 898-3550 Owner BOARD OF ED Occupant Load

Name of facility/Address COASTAL MIDDLE SCHOOL / 170 W. T. RUST RD

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors 10 101-SEC 5
2. Blocked Locked OK 101-SEC 5
3. Exit Sign Good Unsatisfactory NA 101-SEC 5
4. Emergency Lights Good Unsatisfactory NA 101-SEC 5
5. Panic Hardware Good Unsatisfactory NA 101-SEC 5
6. Self-Closing Device Good Unsatisfactory NA
7. Fire Alarm Yes No NA NFPA 72
8. Smoke/Heat Detectors Yes No NA NFPA 73
9. Sprinkler System Yes No TESTING? NA NFPA 13
10. Standpipe Yes No NA NFPA 13
11. Number of Fire Extinguishers 10
Proper Type? Yes No NA NFPA 10
Inspected/Charged Yes No NA NFPA 10
12. Fixed Hood System Yes No NA NFPA 96
13. Date of Last Service 8/06 (REQUIRED EVERY 6 MONTHS)
14. Electrical: Good Fair Unsatisfactory NFPA 70
15. Overloaded sockets/outlets Yes No NFPA 70
16. Missing electrical covers Yes No NFPA 70
17. Other (explain)
18. Excessive Storage of Combustibles Yes No NFPA 30

List Details:

- SPRINKLER SERVICE TAG
- OCCUPANT LOAD CERT.

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Owner/Occupant/Agent Signature

Chatham County Fire Marshal