

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES

FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2006

DATE

10/17/06

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further req that you, as owner, agent or person in charge of structure shall have _____ days to complete specified repairs or improvements.

Bus. Phone 919-3475 Owner CAREY STARK Occupant Load _____

Name of facility/Address GEORGETOWN ELEMENTARY / 1516 KING GEORGE

OCCUPANCY: Business Assembly Storage Educational Day Care Personal Care Home Mercantile Factory Residential Hazardous SCHOOL

COURTESY INSP. ONLY

- 1. Number of Exit Doors MULTI 101-SEC 5
- 2. Blocked _____ Locked _____ OK 101-SEC 5
- 3. Exit Sign Good Unsatisfactory _____ NA _____ 101-SEC 5
- 4. Emergency Lights Good Unsatisfactory _____ NA _____ 101-SEC 5
- 5. Panic Hardware Good Unsatisfactory _____ NA _____ 101-SEC 5
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes No _____ NA _____ NFPA 72
- 8. Smoke/Heat Detectors Yes No _____ NA _____ NFPA 73
- 9. Sprinkler System Yes No _____ NA _____ NFPA 13
- 10. Standpipe Yes No _____ NA NFPA 13
- 11. Number of Fire Extinguishers MULTI
- Proper Type? Yes No _____ NA _____ NFPA 10
- Inspected/Charged Yes No _____ NA _____ NFPA 10
- 12. Fixed Hood System Yes No _____ NA _____ NFPA 93
- 13. Date of Last Service _____ (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No NFPA 70
- 16. Missing electrical covers Yes _____ No NFPA 70
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No NFPA 90

List Details:

- 1 - NON-APPROVED STORAGE IN FIRE SPRINKLER CONTROL RM. (NFPA STANDARD 13)
- 2 - OPEN GAS CONTAINER IN FIRE SPRINKLER CONTROL ROOM (NFPA, STANDARD 30)
- 3 - TABLE/DISPLAY IN HALLWAY (LIFE SAFETY CODE, CH-7)

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Katherine P. ...
Owner/Occupant/Agent Signature

[Signature]
Chatham County Fire Marshal