

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES

FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2006

DATE 10/18/06

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further require that you, as owner, agent or person in charge of structure shall have _____ days to complete specified repairs or improvements.

Bus. Phone _____ Owner Dept of ED Occupant Load _____

Name of facility/Address ISLANDS ELE. / 4595 US HWY 90-E

OCCUPANCY: Business Assembly Storage Educational Day Care
 Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors 20 101-SEC 5
- 2. Blocked Locked _____ OK 101-SEC 5
- 3. Exit Sign Good Unsatisfactory _____ NA _____ 101-SEC 5
- 4. Emergency Lights Good Unsatisfactory _____ NA _____ 101-SEC 5
- 5. Panic Hardware Good _____ Unsatisfactory _____ NA 101-SEC 5
- 6. Self-Closing Device Good Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes No _____ NA _____ NFPA 72
- 8. Smoke/Heat Detectors Yes _____ No TRAILER NA _____ NFPA 73
- 9. Sprinkler System Yes No _____ NA _____ NFPA 13
- 10. Standpipe Yes No _____ NA _____ NFPA 13
- 11. Number of Fire Extinguishers 30
- Proper Type? Yes No _____ NA _____ NFPA 10
- Inspected/Charged Yes _____ No NA _____ NFPA 10
- 12. Fixed Hood System Yes No _____ NA _____ NFPA 93
- 13. Date of Last Service 7/06 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good Fair _____ Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No NFPA 70
- 16. Missing electrical covers Yes _____ No NFPA 70
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No NFPA 30

List Details: - LABEL SPRINKLER ROOM
 - KEEP STORAGE 18' BELOW SPRINKLERS
 - SMOKE ALARM MISSING IN PORTABLE CLASSROOM/OFFICE
 - FIRE ALARM TESTED TO NFPA 72 STANDARDS
 - EXTINGUISHERS TO BE SERVICED YEARLY

The signature below of Owner, Occupant, Agent, signifies inspection was made.
P. Hulstberg
 Owner/Occupant/Agent Signature

RGR 710
 Chatham County Fire Marshal