

APPROVED
DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further require that you, as owner, agent or person in charge of structure shall have _____ days to complete specified repairs or improvements.

Bus. Phone _____ Owner BOARD OF ED Occupant Load 760 857

Name of facility/Address MARSH POINT FLE/ 135 WHITMARSH ISL. RD 110

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous
828

- 1. Number of Exit Doors 12 101-SEC 5
- 2. Blocked _____ Locked _____ OK X 101-SEC 5
- 3. Exit Sign Good _____ Unsatisfactory X NA _____ 101-SEC 5
- 4. Emergency Lights Good _____ Unsatisfactory X NA _____ 101-SEC 5
- 5. Panic Hardware Good _____ Unsatisfactory _____ NA X 101-SEC 5
- 6. Self-Closing Device Good X Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes X No TROUBLE NA _____ NFPA 72
- 8. Smoke/Heat Detectors Yes X No _____ NA _____ NFPA 73
- 9. Sprinkler System Yes _____ No X NA _____ NFPA 13
- 10. Standpipe Yes _____ No _____ NA X NFPA 13
- 11. Number of Fire Extinguishers 20
- Proper Type? Yes X No _____ NA _____ NFPA 10
- Inspected/Charged Yes X No _____ NA _____ NFPA 10
- 12. Fixed Hood System Yes X No _____ NA _____ NFPA 96
- 13. Date of Last Service 8/06 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good X Fair _____ Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No X NFPA 70
- 16. Missing electrical covers Yes _____ No X NFPA 70
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No X NFPA 30

List Details:

- DECORATIVE VEGETATION DOES NOT MEET FIRE CODE FOR INTERIOR FINISH
- ALARM SYSTEM SHOWS TROUBLE SIGNAL
- ARTWORK ON WALLS LIMITED TO 20%
- SEVERAL EMERGENCY LIGHTS OUT
- SEVERAL EXIT LIGHTS OUT

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Henry Mills _____ R 02 710 _____
 Owner/Occupant/Agent Signature Chatham County Fire Marshal