

CHATHAM COUNTY DEPARTMENT OF BUILDING, SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2006

DATE 10/18/06

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshal, stating the defects found to exist in the referenced structure, and further request that you, as owner, agent or person in charge of structure shall have _____ days to complete specified repairs or improvements.

Bus. Phone 958-3980 Owner _____ Occupant Load _____

Name of facility/Address OATLAND ED CENTER / 711 SAND TOWER RD

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors 4 101-SEC 5
2. Blocked 1 Locked _____ OK _____ 101-SEC 5
3. Exit Sign Good _____ Unsatisfactory NA _____ 101-SEC 5
4. Emergency Lights Good _____ Unsatisfactory NA _____ 101-SEC 5
5. Panic Hardware Good _____ Unsatisfactory _____ NA 101-SEC 5
6. Self-Closing Device Good _____ Unsatisfactory NA _____
7. Fire Alarm Yes _____ No NA _____ NFPA 72
8. Smoke/Heat Detectors Yes _____ No NA _____ NFPA 73
9. Sprinkler System Yes _____ No NA _____ NFPA 13
10. Standpipe Yes _____ No NA _____ NFPA 13
11. Number of Fire Extinguishers 6
 - Proper Type? Yes No _____ NA _____ NFPA 10
 - Inspected/Charged Yes No _____ NA _____ NFPA 10
12. Fixed Hood System Yes _____ No _____ NA NFPA 96
13. Date of Last Service _____ (REQUIRED EVERY 6 MONTHS)
14. Electrical: Good _____ Fair _____ Unsatisfactory NFPA 70
15. Overloaded sockets/outlets Yes No _____ NFPA 70
16. Missing electrical covers Yes No _____ NFPA 70
17. Other (explain) _____
18. Excessive Storage of Combustibles Yes No _____ NFPA 30

List Details:

- EXIT DOOR SHOULD OPEN IN DIRECTION OF EGRESS - NFPA 101
- SPRINKLER SYS. REQUIRED IF STAIRCASES NOT RATED 1 HR. - NFPA 101
- HAND RAIL NEEDED ON STAIRS
- EXCESSIVE STORAGE OF COMBUSTIBLES
- SMOKE BARRIERS MAY BE REQUIRED
- STAIRS DO NOT MEET EGRESS CODE

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Annette Quintana
Owner/Occupant/Agent Signature

R. J. [Signature] 710
Chatham County Fire Marshal