

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2008

DATE 2/16/07

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and further that you, as owner, agent or person in charge of structure shall have _____ days to complete specified repairs or improvements.

Bus. Phone 961-3301 Owner DIANE TOWLES Occupant Load _____

Name of facility/Address SOUTHWEST ELEMENTARY/6030 COECHIE RD

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors MULTI
- 2. Blocked OK Locked _____
- 3. Exit Sign Good ✓ Unsatisfactory _____ NA _____
- 4. Emergency Lights Good _____ Unsatisfactory ✓ NA _____
- 5. Panic Hardware Good ✓ Unsatisfactory _____ NA _____
- 6. Self-Closing Device Good ✓ Unsatisfactory _____ NA _____
- 7. Fire Alarm Yes _____ No ✓ NA _____
- 8. Smoke/Heat Detectors Yes _____ No _____ NA ✓
- 9. Sprinkler System Yes _____ No ✓ NA _____
- 10. Standpipe Yes _____ No _____ NA ✓
- 11. Number of Fire Extinguishers MULTI
- Proper Type? Yes ✓ No _____ NA _____
- Inspected/Charged Yes ✓ No _____ NA _____
- 12. Fixed Hood System Yes ✓ No _____ NA _____
- 13. Date of Last Service DEC/06 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good ✓ Fair _____ Unsatisfactory _____
- 15. Overloaded sockets/outlets Yes _____ No ✓
- 16. Missing electrical covers Yes _____ No ✓
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No ✓

101-SEC 5
101-SEC 5
101-SEC 5
101-SEC § 7
101-SEC 5

NFPA 72
NFPA 79
NFPA 13-25
NFPA 13

NFPA 10
NFPA 10
NFPA 98
NFPA 70
NFPA 70
NFPA 70

NFPA 30

List Details:

* NOTE = ALARM SYSTEM NOT TESTED SINCE 2003
1. PRINCIPAL BRIEFED ON FIRE ALARM TESTING
2. SPRINKLER SYSTEMS HAVE YELLOW (NON-COMPLIANT) TAGS

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Diane F. Towles
Owner/Occupant/Agent Signature
(Form 1016-10-01)

[Signature]
Chatham County Fire Marshall

3. EMERGENCY LIGHT OUT 500 WING, 1 OUT GIRLS' RESTROOM, 500 WING, EMER LIGHTS OUT IN ART RM (300)