



STATE FIRE MARSHAL'S OFFICE

716 West Tower, Floyd Building
No. 2 Martin Luther King, Jr. Drive
Atlanta, Georgia 30334

Reviewed by	<i>[Signature]</i>
Date received	<i>8/23/91</i>
File #	
Send to occupant	<i>Yes</i>
Send to owner	<i>Yes</i>
Send to	
Send to	

SPECIAL REQUEST PRIORITY 01
August 16, 1991

Changes Occur

File No. 225-2-004 Name of Building EDOB Kitchen/Auditorium
 Date 8/21/91 Company Name Shelton County Schools
 Name of Facility Bloomingsdale Elementary Owner Grandolyn Goodman
 Address East Main Street Address 208 Hill Street
 City Bloomingsdale State GA Zip 31307 City SAVANNAH State GA Zip 31404
 Phone No. 912-768-4403 Physical Location 101 EAST MAIN ST-ET

Type Occupancy ED CC # _____ Date Issued _____ Construction Type 2-200
 Area 3,000 Occupant Load 145 Sprinklers None Building Imp. 1 of _____
 Standard Used: Pre 1948 1948-1987 LSC 1987 LSC 1988 LSC 1989 LSC Other _____
 Type Inspector: (check one) 80% 100% Follow-up _____ Special Request _____ Amount _____
 # of stories _____ Basement None # of Violations 0 # Violations last insp. 116
 Last Insp. By: ARCHER Date Last Insp: 11/6

Deficiency	Compliance			Deficiency	Compliance		
	Y	N	M		Y	N	M
1. Number of exits?	✓			8. Detecting alarm, open working?	✓		
2. Means of egress of approved type?	✓			9. Emergency alarm systems?	✓		
3. Travel distance to exits?	✓			10. Construction type requirements?	✓		
4. Exit signs?	✓			11. Compartmentation requirements?	✓		
5. Emergency Means of egress illumination?	✓			12. Electrical Systems?	✓		
6. Vertical opening protection?	✓			13. HSC systems?	✓		
7. Interior finish?	✓			14. Other	✓		

Remarks: (Identify any deficiency noted above) Accompanied by: Ch. H. Harkness III, Job Capt.

*Note: There were no Visual Appraisal Code Violations Noted
 I recommend that a Certificate of Occupancy
 be issued under the 1985 LSC NEW. No PBE requirement.*

-1845 C.D.
NO PBE

This acknowledges receipt of a copy of this report, that I accompanied the Fire Safety Compliance Officer during the visit, that an exit briefing was given, and that the NOTICE L-106 was given.

W.K. ALLEN Superintendent W.H. Hall

NOTICE:
 This report shall be returned to the State Fire Marshal's office within N/A days with the delinquency and/or violation noted above corrected (by installing and testing such items) or attaching a Plan of Correction Failure to correct the above noted items and/or violations within the time specified is a violation of the Georgia Safety Fire Law or the I.P. Gas Law, and the appropriate action as required by law will be taken.

Date 8-23-91 By [Signature] Fire Safety Compliance Officer



The Bylaws

XXXXXXXX

XXXXXXXX

STATE FIRE MARSHAL'S OFFICE

716 West Tower, Floyd Building
No. 2 Martin Luther King, Jr. Drive
Atlanta, Georgia 30334

Reported by	<i>JA</i>
Date received	<i>7/27/11</i>
File #	
Send to occupant	<i>"Let Copy"</i>
Send to owner	<i>"Let Copy"</i>
Send to	
Send to	

If Changes Occur

File No. <u>025-E-004</u>	<input type="checkbox"/> Name of Building <u>2001 WING A</u>
Date <u>5-11-91</u>	<input type="checkbox"/> Company Name <u>Chatham County Schools</u>
<input type="checkbox"/> Name of Facility <u>Bloomingsdale Elementary</u>	<input type="checkbox"/> Owner <u>Grandolyn Goodman</u>
<input type="checkbox"/> Address <u>East Main Street</u>	<input type="checkbox"/> Address <u>200 Ball Street</u>
<input type="checkbox"/> City <u>Bloomingsdale</u> State <u>GA</u> Zip <u>31302</u>	<input type="checkbox"/> City <u>Savannah</u> State <u>GA</u> Zip <u>31401</u>
<input type="checkbox"/> Phone No. <u>912-748-4403</u>	<input type="checkbox"/> Physical Location <u>East Main Street</u>

<input type="checkbox"/> Type Occupancy <u>ED</u> CO # <u>ABR1a</u>	Date Issued <u>80-09-21</u> Construction Type <u>11 (Cast)</u>
<input type="checkbox"/> Area <u>8275</u> Occupant Load <u>160</u>	Sprinklers <u>N</u> Egress Insp <u>1</u> of <u>7</u>
<input type="checkbox"/> Standard Used <u>Fire 101A</u> <u>24BEC</u> 1967 LSC 1976 LSC 1981 LSC 1988 LSC Other	
Type Inspection: (circle one) <u>87%</u> 100% Follow-up: <u>Special Request #</u> <u>None</u> <u>Some</u>	
# of stories: <u>1</u> Basement <u>N</u> # of Violations: <u>2</u> # Violations last Insp: <u>0</u>	
Last Insp By <u>Gullford</u> Date Last Insp <u>88-10-11</u>	

Deficiency	Compliance			Deficiency	Compliance		
	Y	N	INA		Y	N	INA
1. Number of exits?				4. Detection alarm comm. systems?			
2. Means of egress of approved type?				5. Egress lighting systems?			
3. Egress protection to exits?				10. Construction type requirements?			
5. Emergency means of egress illumination?				11. Compartmentation requirements?			
6. Means of egress protection?				12. Electrical systems?			
7. Interior finish?				13. HMC systems?			
				14. Other			

Remarks: (Identify any deficiency listed above) Accompanied by: Ms. Annelis R. Appell, As Acquiescing Officer

1. Ex. lights are inoperable with in hallway.
2. Fire Alarm is inoperable.

This report is a record of a finding of the report that I accompanied the Fire Safety Compliance Officer making the report. It is not intended to be a notice of violation and the NOTICE is not given.

Annelis R. Appell *SKINGJEAR* *Annelis R. Appell*

NOTICE:
This report is not intended to be a notice of violation. It is only a record of the findings and of violations found. It does not constitute a notice of violation and it does not constitute a threat of prosecution. Failure to correct the listed violations and/or to take the steps specified in a violation of the Georgia Safety Fire Law or the L.P. Code Laws and the appropriate steps required by the code laws.

Date: 9-16-91 By: Gregory Sullivan
Safety Compliance Officer



STATE FIRE MARSHAL'S OFFICE
 716 West Tower, Floyd Building
 No. 2 Martin Luther King, Jr. Drive
 Atlanta, Georgia 30334

Reviewed by: SHREVE
 Date reviewed: 7-20-91
 File #: 11800
 Sheet to record: 11800-1
 Sheet to owner: 11800-1
 Sent to: _____
 Sent to: _____

If Changes Occur

File No. 898-E-004 Name of Building #002 High R
 Date 7-20-91 Company Name Chatham County Schools
 Name of Facility Bloomington Elementary Owner Guendolyn Goodson
 Address East Main Street Address 300 Hill Street
 City Bloomington State GA Zip 31303 City Marietta State GA Zip 31407
 Phone No. 913-142-4403 Physical Location East Main Street

Type Occupancy: ED CC: 18444 Date Issued: 89-03-22 Construction Type: 11800
 Area: 1960 Occupant Load: 123 Egress: 2 Building Use: R, U, J
 Standard Used: Per IBCS (1989 LSC) 1987 LSC 1978 LSC 1961 LSC 1955 LSC Other _____
 Type Inspection: (circle one) PPS 100% Follow-up: _____ Special Request: (Annual) Semi
 # of stories: 1 Basement: N # of Violations: 2 # Violations last insp: 2
 Last Insp. By: Outboard Date Last Insp: 89-03-14

Deficiency	Compliance			Deficiency	Compliance		
	Y	N	M		Y	N	M
1. Number of exits?	✓			5. Detention alarm comm. systems?	✓		
2. M. Use of egress of approved type?		✓		6. Egress control systems?	✓		
3. Travel distance to exits?	✓			10. Construction type requirements?	✓		
4. Exit signs?	✓			11. Construction type requirements?	✓		
5. Emergency Means of egress illumination?	✓			12. Electrical System?	✓		
6. Vertical openings protection?	✓			13. HVAC systems?	✓		
7. Interior finish?	✓			14. Other	✓		

Remarks (briefly list deficiencies noted above) Accompanied by: Mr. William H. Hill, Mr. H. H. Haggerty

NO.	DEFICIENCY	REMARKS
1.		
2.		
3.		
4.	Tables and chairs in hallway blocking means of egress	OUT OF BUILDING
5.	Exit signs in-Operable in both sets (Normal Emergency)	
6.	Fire Alarm is in-Operable	

I, a certified designee of a copy of this report, that I accompanied the Fire Safety Compliance Officer making this report, that all the deficiencies noted and that the building owner has been notified.

Amelia Tappell Principal Paul Lippell

NOTICE:
 This report shall be returned to the State Fire Marshal's office within 60 days with the deficiencies noted or violations noted above corrected (by initials) and dated each item or attaching a Plan of Correction. Failure to correct the above deficiencies will be considered a violation of the Georgia Safety Fire Law or the L.P. Gas Law and the appropriate action required by law will be taken.

Date: 7-16-91 By: Brian Spilgard
 Fire Safety Compliance Officer



STATE FIRE MARSHAL'S OFFICE
 716 West Tower, Floyd Building
 No. 2 Martin Luther King, Jr. Drive
 Atlanta, Georgia 30334

Inspected by TRUZY
 Date inspected 9-16-91
 File # 91-1047
 Sent to customer Let Copy
 Sent to owner Let Copy
 Sent to _____
 Sent to _____

Change Order
 File No. 026-E-004
 Date 9-16-91
 Name of Facility Bloomington Elementary
 Address East Main Street
 City Bloomington State GA Zip 31302
 Phone No. 812-748-4403
 Name of Building 8008 MADE P
 Company Name Chatham County Schools
 Owner Grandview Bookman
 Address 208 Hill Street
 City Bremen State GA Zip 31109
 Physical Location East Main Street

Type Occupancy ED C.C. # 18139 Date Issued 07-09-88 Construction Type II
 Area 13448 Occupant Load 518 Earthquake III Building Map 15 of 7
 Standard Used: Pre 1948 1948 BEC 1967 LSC 1979 LSC 1981 LSC Other 1981 LSC
 Type Inspection: (circle one) SOA: 100% Follow-up: _____ Special Request # _____ General Special
 # of stories: _____ Basement: _____ # of Violations: _____ # Violations last time: _____
 Last Insp By: Gullford Date Last Insp: 28-08-88

Deficiency	Compliance			Deficiency	Compliance		
	Y	N	U		Y	N	U
1. Number of exits?	✓			8. Detection of alarm systems?	✓		
2. Means of egress of required type?	✓			9. E-Exit systems?	✓		
3. Travel distance to exits?	✓			10. Construction type requirements?	✓		
4. Exit signs?	✓			11. Compartmentation requirements?	✓		
5. Emergency lighting of egress illumination?	✓			12. Electrical systems?	✓		
6. Vertical opening protection?	✓			13. IMAC systems?	✓		
7. Interlock doors?	✓			14. Other			

Remarks (Identify any deficiency noted above) Accompanied by Mr. Joseph P. Russell, Mr. K. Murray
 1. Multi-Phase Adapters in Use in Rooms # 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100
 2. Defective Exit Signs found in Rooms # 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50, 51, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 62, 63, 64, 65, 66, 67, 68, 69, 70, 71, 72, 73, 74, 75, 76, 77, 78, 79, 80, 81, 82, 83, 84, 85, 86, 87, 88, 89, 90, 91, 92, 93, 94, 95, 96, 97, 98, 99, 100
 3. Fire Extinguishers with in need to be serviced and recharged
 4. Tag installed on Extinguisher in Room # 11 in Office of Principal
Electric Cord going under the Paper Machine at the computer has been Spliced together

This is a preliminary report of a code of the report. Full compliance for Fire Safety Compliance Officer making the report.
Joseph P. Russell Principal Paul Pappell

NOTICE: This report shall be returned to the State Fire Marshal's Office within 60 days with the deficiencies and/or violations noted above corrected. The building code official shall submit a Plan of Correction Failure to comply with the above deficiencies and/or violations within the time specified is a violation of the Georgia Safety Fire Law or the I.F. Code Law and the appropriate action is required by the code official.
 Date 9-16-91 by Ziggy Guillford
 Fire Safety Compliance Officer