

SAVANNAH FIRE & EMERGENCY SERVICES

FIRE PREVENTION INSPECTION REPORT



NAME OF INSPECTOR: Bill Barnett
 DATE OF INSPECTION: 8-23-07
 LOCATION: 207 Montgomery Crossroads
 USED AS: Education
 OCCUPANT: Bartlett Middle
 OWNER OR MANAGER: Drema Jackson

Fax 961-3515
 Email drema.Jackson@sccpss.com

DESCRIPTION	RESULTS			LOCATION
	YES	NO	N/A	
1. Illuminated exit signs are operable.	X			
2. Exit doors and locks are easily operable.	X			
3. Exit passageways properly marked.	X			
4. Proper number of exits.	X			
5. Exit access / steps / stairways unobstructed.	X			
6. Smoke detectors operable.	X			
7. Alarm system operable and inspected annually.	X			
8. Sprinkler system checked annually and in service.			X	
9. Sprinkler heads are not blocked per NFPA 13.			X	
10. Electrical wiring, appliances cords safe.	X			
11. Extension cords temporary use only.	X			
12. Fire extinguishers are the proper type.	X			
13. Fire extinguishers are properly mounted.	X			
14. Fire extinguishers operation / current annual tag.	X			
15. Hood fire suppression system operational and inspected / tagged semi – annually.		X		Kitchen
16. Are hood systems / filters free of excessive accumulation of grease?	X			
17. Is the water heater pop-off valve vented?	X			
18. is the water heater free of storage?	X			
19. Heating system area free of storage?	X			
20. Electrical panel boxes properly covered?	X			
21. Maintain 36 inches of clearance in front of electrical panels / boxes / transformers.	X			
22. Are high pressure cylinders secured?			X	
23. Is emergency lighting Fire Code compliant?	X			
24. Handrails securely fasten?	X			
25. Ramps and steps in safe condition?	X			
26. Building free of excessive combustibles: rags, trash, rubbish, ect.	X			
27. Are flammable liquids stored properly?			X	
28. Has the staff had required safety training?			X	
29. Are fire walls & fire resistant construction maintained?	X			

Remarks:

15. Hood system is red tagged noncompliant due to gas valves not closing properly. Have inspected & repaired by licensed contractor.

CORRECTIVE ORDERS:

Correct within 30 days

ALL ITEMS ABATED AS OF 9/27/07

Bill Barnett
 Inspector

IF YOU HAVE ANY QUESTIONS, PLEASE CALL 644-5960