

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2007

DATE 2/26/07

APPROVED
 DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall stating the defects found to exist in the referenced structure, and further that you, as owner, agent or person in charge of structure shall have 30 days to complete specified repairs or improvements.

Bus. Phone 307-6440 Owner BOARD OF EDUCATION Occupant Load NOT UP TO DATE

Name of facility/Address Hesse Ele. / 9116 Whitefield Ave 750

OCCUPANCY: Business Assembly Storage Educational Day Care
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors NO 101-SEC 5
- 2. Blocked 1 Locked _____ OK 9 SPT CORRECTED 101-SEC 6
- 3. Exit Sign Good _____ Unsatisfactory X NA _____ 101-SEC 5
- 4. Emergency Lights Good _____ Unsatisfactory X NA _____ 101-SEC 6
- 5. Panic Hardware Good _____ Unsatisfactory _____ NA X 101-SEC 5
- 6. Self-Closing Device Good _____ Unsatisfactory X NA _____
- 7. Fire Alarm Yes X No _____ NA _____ 8/06 NFPA 72
- 8. Smoke/heat Detectors Yes X No _____ NA _____ NFPA 73
- 9. Sprinkler System Yes X No NO TEST NA _____ NFPA 13
- 10. Standpipe Yes _____ No _____ NA X NFPA 13
- 11. Number of Fire Extinguishers 30
 - Proper Type? Yes X No _____ NA _____ NFPA 10
 - Inspected/Charged Yes X No 1 NA _____ NFPA 10
- 12. Fixed Hood System Yes X No _____ NA _____ NFPA 60
- 13. Date of Last Service 12/06 RED TAG REQUIRED EVERY 6 MONTHS
- 14. Electrical: Good _____ Fair X Unsatisfactory _____ NFPA 70
- 15. Overloaded sockets/outlets Yes _____ No X NFPA 70
- 16. Missing electrical covers Yes X No _____ NFPA 70
- 17. Other (explain) _____
- 18. Excessive Storage of Combustibles Yes _____ No X NFPA 30

List Details: - EXIT LIGHTS OUT, EMERGENCY LIGHTS OUT
- FIRE DOOR BLOCKED OPEN - HOOD RED TAGGED
- OPEN WIRING IN KITCHEN - NO BATTERY IN SMOKE (PORT. GLASS)
- ELECTRIC PANELS BLOCKED BY STORAGE, - NO STROBE IN GYM HORN
- ALARM BUILDS 6mo SERVICE, SPRINKLERS NOT SERVICED YEARLY

The signature below of Owner, Occupant, Agent, signifies inspection was made.

[Signature]
Owner/Occupant/Agent Signature

[Signature] 710
Chatham County Fire Marshall