CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2006 DATE 2/26/07

_____ APPROVED
/ DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall stating the defects found to exist in the referenced structure, and further that you, as owner, agent or person in charge of structure shall have (30) days to complete specified repairs or improvements.

Bus. Phone 303-6572 Owner BOARD OF EDUCATION Occupant Load NOT AVAIL.

Name of facility/Address Isle of Hope Elementary / 100 PARKERSBURG RD

OCCUPANCY: Business (Assembly) Storage (Educational) Day Care
Personal Care Home Mercantile Factory Residential Hazardous

1. Number of Exit Doors 10				101-SEC 5
2. Blocked ____ Locked ____ OK X				101-SEC 5
3. Exit Sign	Good ____	Unsatisfactory X	NA ____	101-SEC 5
4. Emergency Lights	Good ____	Unsatisfactory ____	NA ____	101-SEC 5
5. Panic Hardware	Good ____	Unsatisfactory ____	NA X	101-SEC 5
6. Self-Closing Device	Good ____	Unsatisfactory X	NA ____	
7. Fire Alarm	Yes X	No ____ 7/06	NA ____	NFPA 72
8. Smoke/Heat Detectors	Yes X	No ____	NA ____	NFPA 73
9. Sprinkler System	Yes X	No ____	NA ____	NFPA 13
10. Standpipe	Yes ____	No ____	NA X	NFPA 13
11. Number of Fire Extinguishers 15				
Proper Type?	Yes X	No ____	NA ____	NFPA 10
Inspected/Charged	Yes X	No 2	NA ____	NFPA 10
12. Fixed Hood System	Yes X	No ____	NA ____	NFPA 96
13. Date of Last Service 12/06		(REQUIRED EVERY 6 MONTHS)		
14. Electrical:	Good X	Fair ____	Unsatisfactory ____	NFPA 70
15. Overloaded sockets/outlets	Yes X	No ____		NFPA 70
16. Missing electrical covers	Yes ____	No X		NFPA 70
17. Other (explain) ____				
18. Excessive Storage of Combustibles	Yes ____	No X		NFPA 30

List Details: NO EMERGENCY LIGHTING. FIRE DOORS HELD OPEN. WINDOW IN CORRIDOR NOT FIRE RATED. OVERLOADED SOCKETS. CLEANING EQUIP BLOCKING ELEC. PANELS, NO SMOKE DET. / NON-FUNCTIONAL IN PORT. CLASSROOMS. PORT CLASSES NOT TIED TO FIRE ALARM. 2 EXTG. EXPIRED DECORATIONS / ARTIFICIAL PLANTS NOT FIRE RATED. CERT. OF OCCUPANCY NOT FOUND

The signature below of Owner, Occupant, Agent, signifies inspection was made.

Owner/Occupant/Agent Signature

RGB 710
Chatham County Fire Marshall

I:\forms\fire.inp1