

CHATHAM COUNTY DEPARTMENT OF BUILDING SAFETY AND REGULATORY SERVICES  
FIRE SAFETY INSPECTION DIVISION

YEAR OF: 2006

DATE 2/28/07

APPROVED

DISAPPROVED

You are hereby notified that this is an Official Order of the County Fire Marshall, stating the defects found to exist in the referenced structure, and further that you, as owner, agent or person in charge of structure shall have 30 days to complete specified repairs or improvements.

C/O NOT CURRENT

Bus. Phone 898-3925 Owner Board of Ed Occupant Load 742

Name of facility/Address May Howard Elementary / 115 Wilmington Island Rd

OCCUPANCY: Business Assembly Storage Educational Day Care  
Personal Care Home Mercantile Factory Residential Hazardous

- 1. Number of Exit Doors 10 101-SEC 5
- 2. Blocked \_\_\_\_\_ Locked \_\_\_\_\_ OK X 101-SEC 5
- 3. Exit Sign Good \_\_\_\_\_ Unsatisfactory X NA \_\_\_\_\_ 101-SEC 5
- 4. Emergency Lights Good \_\_\_\_\_ Unsatisfactory X NA \_\_\_\_\_ 101-SEC 5
- 5. Panic Hardware Good \_\_\_\_\_ Unsatisfactory \_\_\_\_\_ NA X 101-SEC 5
- 6. Self-Closing Device Good \_\_\_\_\_ Unsatisfactory X NA \_\_\_\_\_
- 7. Fire Alarm Yes X No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 72
- 8. Smoke/Heat Detectors Yes X No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 73
- 9. Sprinkler System Yes X No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 13
- 10. Standpipe Yes \_\_\_\_\_ No \_\_\_\_\_ NA X NFPA 13
- 11. Number of Fire Extinguishers 20
- Proper Type? Yes X No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 10
- Inspected/Charged Yes X No 2 NA \_\_\_\_\_ NFPA 10
- 12. Fixed Hood System Yes X No \_\_\_\_\_ NA \_\_\_\_\_ NFPA 96
- 13. Date of Last Service 1/07 (REQUIRED EVERY 6 MONTHS)
- 14. Electrical: Good \_\_\_\_\_ Fair X Unsatisfactory \_\_\_\_\_ NFPA 70
- 15. Overloaded sockets/outlets Yes X No \_\_\_\_\_ NFPA 70
- 16. Missing electrical covers Yes \_\_\_\_\_ No X NFPA 70
- 17. Other (explain) \_\_\_\_\_
- 18. Excessive Storage of Combustibles Yes \_\_\_\_\_ No X NFPA 30

List Details: - EXIT LIGHTS OUT, NOT BATTERY EQUIP, EMERGENCY LIGHTS OUT  
- FIRE DOORS BLOCKED OPEN, SMOKE DET NOT WORKING, MISSING. STORAGE NOT ALLOWED IN CLASSROOMS. PULL STATION BLOCKED/MISSING FROM DOOR (WING 5).  
- OVERLOADED EXTENTION CORDS. EXTINGUISHERS OUT OF DATE/BLOCKED.  
- RANGE OVEN IN TEACHERS LOUNGE. DECORATIONS IN HALL/MEDIA CENTER NOT

E/ams, RESTAURANT  
The signature below of Owner, Occupant, Agent, signifies inspection was made.

Owner/Occupant/Agent Signature  
ifformat@fire.insp1

RED 710  
Chatham County Fire Marshall